Energy performance certificate (EPC)			
Unit 11 Nuffield Way ABINGDON OX14 1RL	Energy rating	Valid until: 4 August 2029 Certificate number: 0050-0731-9659-9673-9002	
Property type		B8 Storage or Distribution	
Total floor area		1038 square metres	

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy efficiency rating for this property

This property's current energy rating is D.

Under 0 **A+** Net zero CO2 0-25 Α В 26-50 51-75 С 76-100 D 98 | **D** Ε 101-125 126-150 F Over 150 G

Properties are also given a score. The larger the number, the more carbon dioxide (CO2) your property is likely to emit.

How this property compares to others Properties similar to this one could have ratings: If newly built 30 | B If typical of the existing stock 88 | D

Properties are given a rating from A+ (most efficient) to G (least efficient).

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	50.58
Primary energy use (kWh/m2 per year)	296

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation</u> <u>report (/energy-certificate/0999-7739-5640-0600-5103)</u>.

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name
Telephone
Email

Accreditation scheme contact details

Accreditation scheme Assessor ID Telephone Email

Assessment details

Employer Employer address Assessor's declaration

Date of assessment Date of certificate Doug Whiffen 02476 233144 <u>doug.whiffen@wensleylawz.com</u>

Elmhurst Energy Systems Ltd EES/007512 01455 883 250 <u>enquiries@elmhurstenergy.co.uk</u>

Wensley & Lawz Ltd 116 Walsgrave Road Coventry CV2 4ED The assessor is not related to the owner of the property. 30 July 2019 5 August 2019