

Energy performance certificate (EPC)

Unit 8
The Glenmore Centre Grove Business Park,
Downsview Road
WANTAGE
OX12 9GN

Energy rating

D

Valid until: **9 February 2030**

Certificate number: **0726-9722-5230-0700-7003**

Property type **B8 Storage or Distribution**

Total floor area **163 square metres**

Rules on letting this property


Properties can be let if they have an energy rating from A+ to E.

If a property has an energy rating of F or G, the landlord cannot grant a tenancy to new or existing tenants, unless an exemption has been registered.

From 1 April 2023, landlords will not be allowed to continue letting a non-domestic property on an existing lease if that property has an energy rating of F or G.

Energy efficiency rating for this property

This property's current energy rating is D.



Properties are also given a score. The larger the number, the more carbon dioxide (CO₂) your property is likely to emit.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

44 | B

If typical of the existing stock

118 | E

Properties are given a rating from A+ (most efficient) to G (least efficient).

Breakdown of this property's energy performance

Main heating fuel

Grid Supplied Electricity

Building environment

Air Conditioning

Assessment level

5

Building emission rate (kgCO₂/m² per year)

138.71

Primary energy use (kWh/m² per year)

827

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0920-7277-0450-2020-7064\)](#).

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

| | |
|-----------------|--|
| Assessor's name | David Cadwallader |
| Telephone | 0333 556 0182 |
| Email | dave.cadwallader@meessolutions.co.uk |

Accreditation scheme contact details

| | |
|----------------------|--|
| Accreditation scheme | CIBSE Certification Limited |
| Assessor ID | LCEA162009 |
| Telephone | 020 8772 3649 |
| Email | epc@cibsecertification.org |

Assessment details

| | |
|------------------------|---|
| Employer | CEADA Environmental |
| Employer address | Unit 5 Ram Court, Wicklesham Lodge Farm, Faringdon SN7 7PN |
| Assessor's declaration | The assessor is not related to the owner of the property. |
| Date of assessment | 10 February 2020 |
| Date of certificate | 10 February 2020 |
