

Energy performance certificate (EPC)

Unit 2, Millhill Warehouse Hill Farm Church Lane, Steventon ABINGDON OX13 6SW	Energy rating E	Valid until: 12 March 2029 <hr/> Certificate number: 0720-0431-3429-1297-8006
---	---------------------------	--

Property type

B8 Storage or Distribution

Total floor area

103 square metres


Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

You can read [guidance for landlords on the regulations and exemptions](https://www.gov.uk/government/publications/non-domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance) (<https://www.gov.uk/government/publications/non-domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance>).

Energy rating and score

This property's current energy rating is E.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

47 B

If typical of the existing stock

136 F

Breakdown of this property's energy performance

Main heating fuel

Grid Supplied Electricity

Building environment

Heating and Natural Ventilation

Assessment level

3

Building emission rate (kgCO₂/m² per year)

83.39

Primary energy use (kWh/m² per year)

493

► [About primary energy use](#)

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0970-2948-0421-3720-4010\)](/energy-certificate/0970-2948-0421-3720-4010).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name

David Barrington

Telephone

07800675146

Email

david@davidbarringtonltd.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme

ECMK

Assessor's ID

ECMK300858

Telephone

0333 123 1418

Email

info@ecmk.co.uk

About this assessment

Employer

David Barrington Ltd

Employer address

23 St Martins Street, Wallingford OX10 0AL

Assessor's declaration

The assessor is not related to the owner of the property.

Date of assessment

13 March 2019

Date of certificate

13 March 2019

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at dluhc.digital-services@levellingup.gov.uk or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.